

Product Name: LINEAR PRO MAX

General information

- This luminaire must be installed in accordance with the latest edition of the IET Wiring Regulations and local Building Regulation by a qualified competent person.
- The mains power supply must be turned off before inspection, installation or removal of the luminaire, ensuring that the supply is locked off to prevent inadvertently switching the supply on.
- It is the installer's responsibility to ensure that the installation is suitable for the total load of the luminaire(s). The supply cable fuses/circuit breakers must be correctly rated for the electrical load and taking into account for any transient inrush currents that may occur.
- It is the installer's responsibility to ensure that the environmental operating and storage conditions are complied with and that any fire risks are considered.
- Do not perform insulation strength or insulation resistance tests on the installation with the luminaire(s) connected, this can damage the luminaires and give erroneous readings.
- Do not loop-in supply cables at the luminaire supply terminals unless there is provision for 2-way connection at the terminals.
- The light source contained in this luminaire must only be replaced by TamLite Lighting or an appointed service agent.
- Emergency lighting luminaires must be installed and maintained in accordance with the emergency lighting standard BS 5266-1.
- To ensure that the product warranty remains valid, the luminaire must be installed and maintained in accordance with these installation instructions and the product must not be modified in any way.












Luminaires marked with this symbol must not be covered with thermally insulating material.











This symbol on covers over light sources indicates dangerous live parts do not operate the luminaire with this cover removed.


Dimensions

		A (mm)	B (mm)	C (mm)
LPMFEB		237	70	65
LPMFIB		383	70	65
LPMFIT		1596	70	65
LPMFIT10		3034	70	65
LPMFMT		1584	45	65
LPMFMT10		3022	45	65
LPMFET		1450	70	65
LPMFET10		2888	70	65
LPM5		1438	26	65

Product Name: LINEAR PRO MAX

<p>1</p>  <p>Feed In Trunking Feed End Trunking</p> <p>Remove the product from its packaging.</p>	<p>2</p>  <p>Secure the brackets to the ceiling with a maximum distance of 2500mm.</p>
<p>3</p>  <p>Suspension only</p> <p>Install suspension points to mounting surface within max distance 2500mm</p>	<p>4</p>  <p>Suspension only</p> <p>Install suspension clutches in to brackets and adjust the length by pulling the wire.</p>
<p>5</p>  <p>Pull the lock handle and detach the LED tray from the trunking.</p>	<p>6</p>  <p>Mount the luminaire body into the brackets.</p>
<p>7</p>  <p>Feed In Box Feed In connector</p> <p>Drill the supply cable entry point in the end cap.</p>	<p>8</p>  <p>Connect the Feed In Box or the Feed In Connector to the trunking.</p>


Product Name: LINEAR PRO MAX




Page 3 of 4

Tamlite Technical
Stafford Park 12,
Telford, Shropshire,
TF3 3BJ

+44(0)1952 292441
technical@tamlite.co.uk
Document No: V1



17



Re-attach the LED tray, push the lock handles to lock it in place. Attach the feed box covers.